



Rapid Alert System for dangerous non-food products

| | |
|--|--|
| Alert number | A12/1773/16 |
| Category | Construction products |
| Risk level | Serious risk |
| Product user | Consumer |
| Product | Smoke detector |
| Brand | Haichen |
| Name | First Alert Smoke Alarm |
| Type/number of model | LX-222 |
| Batch number/Barcode | 8 341790 000101 |
| OECD Portal Category | 91000000 - Safety / Security / Surveillance |
| Description | White smoke detector in clear plastic and black cardboard packaging. |
| Country of origin | Unknown |
| Notifying country | Malta |
| Risk type | Fire |
| Risk description | The smoke detector can be installed and fitted to the ceiling without a battery. This could lead to a fire not being detected before it spreads. The product does not comply with the relevant European standard EN 14604. |
| Measures adopted by notifying country | Measures ordered by public authorities: Withdrawal of the product from the market |
| Images | |