Electrium Recall Notice

Dear Customer

Our records show that you have purchased a product that is subject to a recall by Electrium. The products concerned are Miniature Circuit Breakers, and populated Consumer Units with MCBs fitted. If you have installed these products please visit the Electrium exchange web site or dial the following number to register:

www.mcbexchange.co.uk/electrium

0844 556 4787

Electrium will offer a free of charge product inspection and, if necessary, replacement service. The number of problems experienced is small but relatively serious with a risk of overheating and possible burning. Please deal with this as a matter of priority.

nspecting MCB Date Codes


Products affected

Wylex NSB	Crabtree (Loadstar only)	Volex VB
NSB06	6M1B06	VB06
NSB10	6M1B10	VB10
NSB16	6M1B16	VB16

- Each product has a date code printed on its side.
- This code is a 6 letter code e.g. IRSWRA
- However, only the last four letters need to be used in this check as shown.
- Compare the last four letters to the table below.
- If any 6A 10A or 16A MCBs match date codes, please return them to Electrium using your normal returns procedure, phone 01543 438326 for a returns reference number.

Ratings and Date Codes to check for

The state and to street to	0.1000	
6A &10A MCB	16A MCB	
RIRA RERA	RIRA	RERA
RTRA RARA	RTRA	RARA
RCRA SRRA	RCRA	SRRA
RHRA SSRA	RHRA	
RGRA	RGRA	



Typical Miniature Circuit Breaker (MCB)